

**From:** Marjan Jelenko [mailto:Marjan.Jelenko@teb.si]  
**Sent:** mardi 12 juin 2012 16:14  
**To:** ENTSOE Secretariat  
**Cc:** Tomislav Malgaj  
**Subject:** Responses to Consultation on Draft Code on Balancing

Dear Sirs,

First of all thank you for your efforts on the matter concerning liberalization of the gas markets in EU. We in Termoelektrarna Brestanica reviewed the Draft Code on Balancing and we agree with most of Articles. Since Termoelektrarna Brestanica is a peaking power plant we have a question regarding specific rules the similar power plants in EU have. Most of peaking power plants used gas like fuel are „emergency” power plants for System Operators for Electricity, this means it is impossible to predict startup of these units and consequently it is impossible to foresee gas fuel consumption in advance.

The Code on Balancing has a solution with re-nominations, but a standard two hour lead time for re-nominations is too long for this purpose. Our suggestion is cut this time or to find a solution which allows immediate use of gas from the gas network with adequate penalties. I hope that our comment is understandable in opposite please don't hesitate to contact me.

Yours faithfully,

**Marjan Jelenko**  
Production manager  
**Termoelektrarna Brestanica d.o.o.**  
**CPB 18, 8280 Brestanica**

**Tel:** +386 (0) 7 48 16 149  
**Fax:** +386 (0) 7 49 71 288  
**GSM:** +386 (0) 41 626 265  
**E-mail:** [marjan.jelenko@teb.si](mailto:marjan.jelenko@teb.si)  
**Web:** [www.teb.si](http://www.teb.si)